

ERC సెక్యూలి హైదరాబాద్

ERC లో ఫిర్యాదు చేయుట కొరకు నాగర్ కర్నూలు జిల్లా తరపున మా యొక్క విజ్ఞప్తి

- (1) జిల్లాలో HT లైను చాలా సంవత్సరాల కింద లాగడం జరిగింది. అట్టి లూజ్ లైన్ కింద ఇంటర్ ఫూల్స్ వేయుట గురించి
- (2) బిజినాపల్లి మండల కేంద్రంలో ఉన్న అన్ని గ్రామాలకు లో వోల్టేజ్ వల్ల విద్యుత్తు అంతరాయము కలుగుచున్నది. కాబట్టి బిజినాపల్లి పరిసర ప్రాంతంలో 33 కెవి లైన్ రోజుకు సుమారు నాలుగు ఐదు సార్లు అంతరాయం ఏర్పడడం జరుగుతుంది. దీనివల్ల రైతుల పంట పొలాలు సరైన విద్యుత్ లేక ఎండిపోయి రైతులు ఇబ్బంది పడుతున్నారు. ఇట్టి సమస్యను నివారించుట గురించి.
- (3) నంది వడ్డేమాన్ సబ్స్టేషన్ నుంచి అగ్రికల్చర్ కు మరియు గ్రామానికి ఒకే పీడరు ఉంది గ్రామంలో లైట్స్ వేసినప్పుడు కానీ ఏ చిన్న పనికి అయినా ఎల్సి తీసుకున్నప్పుడల్లా అగ్రికల్చర్ కు ఇబ్బంది కలుగుతుంది కావున సపరేట్ పీడర్ ఏర్పాటు చేయుట గురించి.

నోట్:- (గత సంవత్సరము కూడా ఈ పీడర్ సపరేట్ చేయాలని ERC లో ఫిర్యాదు చేయడం జరిగింది అయినా ఇప్పటివరకు ఎలాంటి పని జరగలేదు).

ఇట్లు

జిచంద్రయ్య

కార్యవాయిస ట్రాన్స్ ఫార్మర్లు గిచ్చిమ్మిమెట్లు
'వాళ్ళ' అనుభావనలు తెలుసు.

భారతీయ కిసాన్ సంఘ్ జిల్లా కార్యదర్శి

H.no 5-15,


నంది వడ్డేమాన్ గ్రామం

బిజినాపల్లి మండలం

ఫోన్ నెంబర్ పా.20.

నాగర్ కర్నూల్ జిల్లా Pin code no 509215.

చరవాణి:-9492992069.



From
Divisional Engineer Elecl.,
Operation, Nagarkurnool

To
The Superintending Engineer,
Operation, Nagarkurnool.

54

Lr.No.DEE/OP/NGKL/Tech /D.No. 1106 /25, Date. 22.05 - 2025

Sir,

Sub:- Electrical Operation Division Nagarkurnool – Accident ID NGKNL2436225–Non-Departmental Fatal Electrical Accident occurred On 13.09.2024 at about 02:00 Hrs to 1No buffalo belongs to Srimanthula Shivalingam S/o Bachanna at H.No 1-64, Aurasipally (V), Nagarkurnool (M), Nagarkurnool(Dist). - Submission of detailed report– Reg.


Ref:- 1) Lr.No.ADE/Operation / NGKL / D.No. 134/25 Dt: 29.04.2025

The accident report received vide above reference 1st cited from the Asst. Divisional Engineer/Operation/Nagarkurnool pertaining to Non-Departmental Fatal Electrical Accident occurred On 13.09.2024 at about 02:00 Hrs to 1No buffalo belongs to Srimanthula Shivalingam S/o Bachanna at H.No 1-64, Aurasipally (V), Nagarkurnool (M), Nagarkurnool(Dist) is herewith submitted..

Further it is to submit that the Asst.Divisional Engineer/Operation/Nagarkurnool has reported that at the time of accident While Buffalo grazing on the field near by B.Shivalinga agriculture land accidentally touched the snapped Conductor wire which fallen on the ground last night due to heavy gale and wind. Immediately the buffalo got electrical shock and died on the spot.

- Encl:- 1) Online Entry Sheet
2) Preliminary Report
3) Detailed Report
4) Sketch
5) Party Application
6) Owner Certificate
7) Veterinary Death Certificate
8) Aadhar Card Copy
9) Post mortem report
10) Witness Statements

Yours faithfully



Divisional Engineer Elecl.,
Operation, Nagarkurnool

(SBE)

Copy to Asst. Divisional Engineer/Operation/ Nagarkurnool
Copy Submitted to the Chief Electrical Inspector, Mint Compound, Hyderabad

22.05.2025 5:55 PM