


శ్రీమత కె.ఎం.వీ.ఎస్.ఆర్ కార్యకర్తల గారు.

ERC హైదరాబాద్ సమక్షమునకు.

విషయం:- పరిహారము కార్యక్రమం

మనది అభివృద్ధి! మాని కేరళా రాష్ట్రం -
 చిత్రాపూర్ జిల్లా కమిషనరీలు: మా మామూల
 2021 సం||లో ఆర్థికంగా కష్టపడితే తరల
 కార్యక్రమంగా పనిచేయాలన్నారు. ADE గారికి
 దరఖాస్తు చేస్తున్నాము. కొన్ని భూమి విషయం గల
 సం|| ERC సమక్షంలో మీ ద్వారా ఆ
 వచ్చినాము కొన్ని మాకు చిలాట పరిహార
 తీంద లేదు. మీరు భూమి విషయం చివరి నాడు
 చెప్పామని చెప్పియుంటేరి చిలాట పరిహార
 బిల్డింగు ఆడుకొనలేని మనవి.

సూచన: ADE గారి వద్దకు
 రికార్డులు పంపించండి.



ప్రస్తుత
 N. వెంకటేశ్వర్లు
 గ్రామ కేరళా -
 పంపించండి: కమిషనరీ
 జిల్లా చిత్రాపూర్
 పోస్టు: కమిషనరీ కేరళా

phone 9849127346

SOUTHERN POWER DISTRIBUTION COMPANY OF TS LTD.

PRELIMINARY REPORT OF ACCIDENT

Lr. No. ADE / OP / VIKARABAD / F. No. Accident / D.No. ²⁹⁴⁸ 24. Dt: 22 - 3 - 2025.


1. Date of Accident : 12.06.2021 at 12:00 Pm.
2. Date and Time of Report : 21.03.2025 at 12.25 Pm
3. Name and Designation of reporting Officer : Sri. P. Saiyanarayana Reddy, ADE / OP / VKB
4. Location of Accident : Kerelly (V)
Dharur (M), Vikarabad District
5. Name of Casualty : N. Chandra Reddy S/o Manik Reddy
6. Residence of Casualty : Kerelly (V)
7. Occupation of Casualty : Farmer
8. (Department & Non Departmental) : Non - Departmental
9. Causes of Accidents

According to the information received
It is known that the deceased while shifting
the iron rod during the house construction,
accidentally got in touch with nearby 11KV
line and got Electrocuted. He immediately
shifted to hospital at Hyderabad. Unfortunately
the victim died while undergoing treatment.

10. Clarification (Fatal & Non fatal)
(Departmental & Non Departmental) : Fatal, Non-Departmental
11. Voltage of Earth : LT Line
12. Whether informed to police : Yes
13. (if so state the crime number) : 112/2021
14. Action taken to prevent Reoccurrence : -

Any other Remarks

All the staff and consumers are advised to not
to touch electrical equipments without Safety guards



(Signature)
Asst. Divisional Engineer,
Operation : Vikarabad.

Submitted to:
The Divisional Engineer, Elect, Operation, Vikarabad.
The Superintending Engineer, Operation, Vikarabad.
The Deputy Electrical Inspector, RR-I Sub-Division, H.No.1-8-499/10, Chikkadpally, Hyderabad 500020.