

Commission Secretary.

===== Forwarded message =====
From: Surya prakasa Rao <spradvisor@gmail.com>
To: "ceipc&ractgrpdccl" <ceipcractgrpdccl@gmail.com>
Cc: <secy-tgerc@telangana.gov.in>
Date: Thu, 21 May 2026 18:11:12 +0530
Subject: Re: Rejoinder on Submission of response.
===== Forwarded message =====

Sir,

Thank you for the replies on my suggestions in response to the public notice for grant of distribution licence to TGRPDCL.

However, I am surprised to note that TGRPDCL doesn't recognise the importance of segregation of Agricultural feeders at 33/11kv substations. In item 4, it is stated that segregation of feeders is CAPEX intensive with minimal benefits and that 24 hours supply is being given to agricultural consumers.

This contention of minimal benefits is grossly misconceived and is highly detrimental to the very objective providing efficient and quality supply to agricultural consumers for which the TGRPDCL is formed.

I Hope that Hon'ble Commission will make appropriate provisions in the licence conditions on segregation of Agricultural feeders.

Thanking you,

Regards,
S. Surya Prakasa Rao
Former Director (Commercial), erstwhile APCPDCL, and
Former Secretary, erstwhile APERC,
Flat. No. 105, Ashok Chandra Enclave,
11-4-660, Redhills, Hyderabad -500004

Mobile : 9392272754

On Thu, 21 May 2026, 16:58 ceipc&ractgrpdccl, <ceipcractgrpdccl@gmail.com> wrote:
Sir,

Please find the attachment for the response to the objection raised on Licensee application of TGRPDCL.

Yours Sincerely,
Chief Engineer,
IPC&RAC,TGRPDCL.